

# GM200-1A, GM400-1A GM200-2A, GM400-2A Operating Manual



2025.5

# LONGER

#### Baoding Longer Precision Pump Co., Ltd.

Add: 3rd/4th Floor, Building 6B, University Science Park Baoding National, High - Tech Industrial Development Zone Baoding, Hebei, China 071051

Tel: 86 - 312 - 3110087 3138553

Fax: 86 - 312 - 3168553

E - mail: longer@longerpump.com Http://www.longerpump.com



Mini Peristaltic Pump

Baoding Longer Precision Pump Co.,Ltd.

A Halma company

# **Contents**

| Contents  | _    |
|---|------|
| 1.General Information · · · · · · · · · · · · · · · · · · ·                       |      |
| 1.1 Statements · · · · · · · · · · · · · · · · · · ·                              |      |
| 1.2 Precautions·····  |      |
| 1.3 Contacts  |      |
| 2. Product Introduction · · · · · · · · · · · · · · · · · · ·                     |      |
| 2.1 Main Features · · · · · · · · · · · · · · · · · · ·                           |      |
| 2.2 Unpacking·····  |      |
| 2.3 System Structure and Dimensions · · · · · · · · · · · · · · · · · · ·         |      |
| 2.3.1 Outline Dimensions·····   |      |
| 2.3.2 Pump Interfaces·····  |      |
| 2.3.3 GM200-1A/GM400-1A Remote Control Port · · · · · · · · · · · · · · · · · · · | • 6  |
| 2.4 Technical Specifications · · · · · · · · · · · · · · · · · · ·                | • 9  |
| 2.5 Applicable Tubing and Flow Rate·····  | • 10 |
| 3. GM200-2A/GM400-2A Operating Instructions · · · · · · · · · · · · · · · · · · · | • 10 |
| 3.1 Keypad and Display · · · · · · · · · · · · · · · · · · ·                      |      |
| 3.1.1 Keypad Function · · · · · · · · · · · · · · · · · · ·                       |      |
| 3.1.2 LCD Display·····  |      |
| 3.2 Operating Instructions·····   | • 13 |
| 3.2.1 Power Up  |      |
| 3.2.2 Set the Work Mode · · · · · · · · · · · · · · · · · · ·                     |      |
| 3.2.3 Display Pump Speed or Time······  |      |
| 3.2.4 Set the Timer Duration · · · · · · · · · · · · · · · · · · ·                | . 1  |
| 3.2.5 Start and Stop · · · · · · · · · · · · · · · · · · ·                        | · 1! |
| 3.2.6 Change the Direction · · · · · · · · · · · · · · · · · · ·                  |      |
| 3.2.7 Prime the Pump · · · · · · · · · · · · · · · · · · ·                        |      |
| 3.2.8 Increase and Decrease Pump Speed·····                                       | . 1  |
| 3.2.9 Keypad Lock······   | · 1  |
| 3.2.10 Footswitch Control Start and Stop · · · · · · · · · · · · · · · · · · ·    | . 1  |
|   |      |

| 4 .GM200-1A/GM400-1A Operating Instructions $\cdots 18$   |
|---|
| 4.1 Keypad and Display · · · · · · 18                     |
| 4.1.1 Keypad Function · · · · · 18                        |
| 4.1.2 LCD Display   |
| 4.2 Power Up  |
| 4.3 Set the Work and Control Mode · · · · · 23            |
| 4.4 Manual Operating · · · · · · 25                       |
| 4.4.1 Display Pump Speed or Time · · · · · · · 26         |
| 4.4.2 Set the Timer Duration · · · · · 26                 |
| 4.4.3 Start and Stop · · · · · · 27                       |
| 4.4.4 Change the Direction · · · · · · 27                 |
| 4.4.5 Prime the Pump · · · · · 28                         |
| 4.4.6 Increase and Decrease Pump Speed······29            |
| 4.4.7 Keypad Lock · · · · · · · · · · · · · · · · · 29    |
| 4.5 Footswitch Control Start and Stop·····29              |
| 4.6 External Signal Control · · · · · · 30                |
| 4.6.1 Set the Control Mode · · · · · · 30                 |
| 4.6.2 Start and Stop·····32                               |
| 4.6.3 Change the Direction · · · · · · 33                 |
| 4.6.4 Increase and Decrease Pump Speed······34            |
| 4.6.5 Manual Emergency Stop····· 35                       |
| 4.6.6 Display Pump Speed or Accumulated Time······35      |
| 4.6.7 Keypad Lock   |
| 4.7 Communication Control · · · · · · 36                  |
| 4.7.1 Enter and Exit RS485 Mode······36                   |
| 4.7.2 Set the Communication Parameters · · · · · · · · 37 |
| 4.7.3 Set the Continuous or Timer Mode · · · · · · · 38   |
| 4.7.4 Manual Emergency Stop····· 39                       |
| 4.7.5 Display Pump Speed or Time······40                  |
| 4.7.6 Keypad Lock 40                                      |
| Appendix A Factory Default Settings $\cdots 41$           |
| Appendix B Modbus Register Definition 42                  |
| Appendix C Longer Pump OEM Protocol · · · · · · 48        |

#### 1. General Information

#### 1.1 Statements

- Longer Pump adheres to a strategy of continuous product improvement. The upgrades, modifications or change to the pumps appearance, specification or software may occur without prior notice.
- Depending on the pump model and software version you are using, the screenshots or function descriptions in this manual may be different, please refer to the functions of the current software version.
- The pumps shown in the manual are for illustration purposes only and may differ from the actual products. Please refer to the actual items.

#### 1.2 Precautions

- The housing of the drive is provided with grounding terminal. In order to guarantee the operator's safety and improve the electromagnetic compatibility of the equipment, please ground the product reliably.
- Please do not disassemble, refit or maintain the product without permission, so as to avoid any damage or reduction to its performance.
- All ports on the rear housing of the drive must be protected against vapor and water ingress. Ensure all ports are either connected with cables or sealed with protective covers.
- If tubing leaks or bursts, fluid may spray from the tubing and pump head. Take reasonable practicable measures to ensure the operators' safety.
- Make sure fluid in the tubing has been drained out, that there is no
  pressure in the pipeline and disconnect pump from mains power, while
  removing or replacing the tubing.
- Disconnect the pump from the mains power before connecting the control signal wire.
- Do not touch the rotor while pump is running.
- Release the compression block when pump stops running for a long time to avoid tubing deformation caused by occlusion.
- Keep the rotor clean and dry to avoid tubing excessive wear and premature failure of pump head or drive.

- Please do not add the lubricating oil to the rotor by yourself, any improper operation could corrode the pump head housing or dislocate the tubing.
- Please connect the power cord or foot switch in correct way, and do not damage the plug.
- If the pump head can't resist organic solvent and corrosive liquid, please clean the liquid left on the surface of the pump head in time.

#### 1.3 Contacts

- Baoding Longer Precision Pump Co., Ltd.
- Address: Floor 3-4, Block B, Building 6, University Science Park, No. 5699
   North Second Ring Road, National High-tech Industrial Development
   Zone, Baoding City, Hebei Province, China
- Telephone: +86-312-3110087
- Website: www.longerpump.com

#### 2. Product Introduction

#### 2.1 Main Features


- Compact size and structure, space saving footprint with a stackable design.
- Features physical button operation and a LCD display for intuitive and convenient use.
- Provides continuous and timer modes for different applications.
- High speed control accuracy up to  $\pm 0.1\%$ .
- GM200-2A and GM400-2A can be controlled by keypad or a footswitch.
- GM200-1A and GM400-1A can be controlled by keypad, footswitch, external signals and RS485 communication commands.
- Excellent EMC performance certified by TUV and compliant with both lab standard EN IEC 61326 and industrial standard EN IEC 61000.
- Mounted with a 4-roller pump head BPH01 for low pulsation and longer tubing life.


# 2.2 Unpacking

- (1) Remove the pump and the accessories from the shipping carton.
- (2) Check the packing list to confirm all accessories are included.
- (3) In case of any questions, please contact Longer Pump or the local distributor.

# 2.3 System Structure and Dimensions


#### 2.3.1 Outline Dimensions






GM200-1A/GM400-1A/GM200-2A/GM400-2A with BPH01 Pump Head

# 2.3.2 Pump Interfaces



GM200-1A/GM400-1A


5



GM200-2A/GM400-2A

To enhance the EMC performance of the pump, it is recommended to connect the grounding knob to the system's protective earth (PE).

# 2.3.3 GM200-1A/GM400-1A Remote Control Port



| Pin | Function | Description  | Wiring Instruction  |
|-----|----------|--|---|
| 1   | V/F      | Speed signal 0-5V/0-10V/0-10kHz input terminal: by default, the 0-5V/0-10V/0-10kHz signal linearly corresponds to 0-200rpm or 0-400rpm. The relationship between the signal range and speed range can be configured through communication commands. Refer to Appendix B, Modbus Register Definition.   | (1)Wiring diagram when the speed signal is 0-10kHz/0-5V/0-10V:  1 6 13 START CW/ 0-5V 9-10kHz 8/11  |
| 2   | В        | RS485-B  | 9———  |
| 3   | A        | RS485-A  | (2) Wiring diagram when the speed signal is 4-20mA:   |
| 4   | 5V       | DC5V output, Max 10mA  | 14  |
| 5   | NC       | Reserved   | 6   |
| 6   | cw/ccw   | Pump running direction control signal input. The default factory trigger logic is level trigger (momentary): The contact between Pin 6 and Pin 8 is open, or Pin 6 receives a high level signal, pump runs clockwise. The contact between Pin 6 and Pin 8 is closed, or Pin 6 receives a low level signal, pump runs counterclockwise.  The trigger mode can be configured via communication commands to either level trigger (momentary) or pulse trigger (maintained). Refer to Appendix B Modbus Register Definition. | (3) In the external control modes, the Pin 13 and Pin 6 can receive logic level signal (pump will operate in different status when receives a 5-24V level signal or a low level signal) or dry contact signal.  8/11 13 8/11 13 |
| 7   | NC       | Reserved   |   |
| 8   | GND      | GND  | 5V-24V Dry Contact  |
| 9   | AGND     | GND for the speed signal.  | 8/11 6 8/11 6   |
| 10  | DIR_EN   | In keypad control mode, the pump running direction can be controlled by an external signal.  The contact between Pin 10 and Pin 8/11 is closed: direction key of the keypad is disabled, and the direction is controlled by the input signal to Pin 6.  The contact between Pin 10 and Pin 8/11 is open: direction key of the keypad is enabled, and the direction is controlled by the direction key.   | 5V-24V Dry Contact  (4) In keypad control mode, control the start/stop by external signal:  12  13  START /STOP 8/11  |
| 11  | GND      | GND  | 0/11  |

7

| Pin | Function   | Description   | Wiring Instruction  |
|-----|------------|---|---|
| 12  | SS_EN      | In keypad control mode, the pump start/stop can be controlled by an external signal.  The contact between Pin 12 and Pin 8/11 is closed: start/stop key is disabled, and the start/stop is controlled by the input signal to Pin 13.  The contact between Pin 12 and Pin 8/11 is open: start/stop key is enabled, and the start/stop is controlled by the start/stop key.   |   |
| 13  | START/STOP | Pump start/stop control signal input. The default factory trigger logic is level trigger (momentary): The contact between Pin 13 and Pin 8 is open, or Pin 13 receives a high level signal, pump runs. Contact between Pin 13 and Pin 8 is closed, or Pin 13 receives a low level signal, pump stops. The trigger mode can be configured via communication commands to either level trigger (momentary) or pulse trigger (maintained). Refer to Appendix B, Modbus Register Definition. | (5) In keypad control mode, control the running direction by external signal:  10 |
| 14  | mA         | Speed signal 4-20mA input terminal: by default, the 4-20mA signal linearly corresponds to 0-200rpm or 0-400rpm. The relationship between the signal range and speed range can be configured through communication commands. Refer to Appendix B, Modbus Register Definition.  |   |
| 15  | NC         | Reserved  |   |

# 2.4 Technical Specifications

|                                | GM200-1A   | GM400-1A   | GM200-2A  | GM400-2A                            |
|--------------------------------|--|--|---|-------------------------------------|
| Pump speed                     | 0-200rpm   | 0-400rpm   | 0-200rpm  | 0-400rpm                            |
| Speed resolution               |  | 0.01 rpm (speed<1<br>0.1rpm (10rpm≤speed<br>1rpm (100rpm≤speed≤  | d<100rpm)   |                                     |
| Display                        | LCD screen for pump  | speed, running direction,  | time, start/stop stat   | us and work mode                    |
| Running direction              | Clockwise  | or counter-clockwise, car  | n be toggled during r   | unning                              |
| Work mode                      |  | Continuous or tim  | ner mode  |                                     |
| Control mode                   |  | footswitch,<br>ommunication control  | Keypad or foo   | tswitch control                     |
| Keypad control                 | Set the parameters and control the pump via keypad: start/stop, running direction, prime status, speed adjustment, work mode, control mode, timer, communication control parameters  |  | Set the paramete<br>the pump via key<br>running direction<br>speed adjustmen<br>timer | pad: start/stop,<br>, prime status, |
| External control               | Start/stop: switch signal, level trigger or pulse trigger Running direction control: switch signal, level trigger or pulse trigger Speed control: 4-20mA/0-5V/0-10V/0-10kHz. The relationship between the signal range and speed range can be configured through communication commands. |  | N/A   |                                     |
| Communication control          |  | e, Modbus RTU<br>nger OEM protocol   | N   | /A                                  |
| Footswitch control             |  | Control the start/stop via   | a footswitch  |                                     |
| Timer function                 | In time mode, th   | e pump runs and stops b<br>Timer range: 0.1s   |   | er duration.                        |
| Runtime counter                | In continuous mode, the pump automatically records the runtime and can accumulate the multiple operation periods (reset upon power-up). Timing range: 0.1s-999h  |  |   |                                     |
| Keypad lock                    | To prevent misoperation  |  |   |                                     |
| Pump status<br>when powered up | set to the status before   | Timer mode: stop Continuous mode: stop as default, can be set to the status before power-off via communication command |   | ор                                  |
| Parameter retention            | Run and system parameters are saved after power loss in both keypad control and communication control modes.   |  |   |                                     |

9

| Prime                    | Fast filling or emptying at full speed   |  |  |  |
|--------------------------|--|--|--|--|
| Certificates             | CE,UKCA<br>EMC standard: EN IEC 61326-1:2021, EN IEC 61000-6-1:2019, EN IEC 61000-6-<br>2:2019, EN IEC 61000-6-3:2021, EN IEC 61000-6-4:2019 |  |  |  |
| Dimensions<br>(L*W*H)    | 220mm x 115mm x 135mm (including pump head)  |  |  |  |
| Power supply for adapter | AC100-240V, 50Hz-60Hz  |  |  |  |
| Power supply for pump    | DC24V/8W DC24V/16W DC24V/8W DC24V/16W  |  |  |  |
| Working condition        | Environment temperature:0°C-40°C, relative humidity:<80%   |  |  |  |
| IP rating                | IP31   |  |  |  |
| Weight                   | 1.35kg (including pump head)   |  |  |  |

# 2.5 Applicable Tubing and Flow Rate

| Pump Head     | Τι                         | bing                       | Max Flow Rate Reference (mL/min) |                      |
|---------------|----------------------------|----------------------------|----------------------------------|----------------------|
| Рипр пеац     | Silicone Tubing            | PharMed® Tubing            | GM200-1A<br>GM200-2A             | GM400-1A<br>GM400-2A |
| dPOFLEX BPH01 | 13#, 14#, 19#,<br>16#, 25# | 13#, 14#, 19#,<br>16#, 25# | 170                              | 340                  |

# 3. GM200-2A/GM400-2A Operating Instructions

# 3.1 Keypad and Display




#### 3.1.1 Keypad Function





When the pump stopped, press the Mode Key to toggle the work mode between continuous mode and timer mode.

#### 3. 1.2 LCD Display



| Icon     | Name                  | Description  | Remark               |
|----------|-----------------------|--|----------------------|
|          | Run                   | This icon will be displayed when the pump is running   | Only one icon can be |
|          | Stop                  | This icon will be displayed when the pump is stopped   | displayed at a time. |
| <b>♦</b> | Counter-<br>clockwise | This icon will be displayed when the pump is running counter-clockwise.  | Only one icon can be |
| C        | Clockwise             | This icon will be displayed when the pump is running clockwise.  | displayed at a time. |
| 8        | Keypad<br>Lock        | The lock icon appears when the keypad is locked and disappears when the keypad is unlocked.  |                      |
| 0        | Timer                 | The timer icon indicates that the pump is running in timer mode. When the icon is not displayed, the pump is running in continuous mode. |                      |

| 888 | Speed or<br>Time | 1. Displays the current pump speed with unit of "rpm" Displays "" when pump is in the prime status. 2. Displays time with unit of "sec, min or hr": a. Pump stopped in the timer mode: displays the set timer duration. b. Pump running in the timer mode: displays the remaining time (countdown). c. Continuous mode: displays the accumulated run time. | 1. In timer mode, the pump can not be paused. When restarted, the countdown time will begin from the full set duration. 2. In continuous mode, the accumulated run time can be reset by the Clear Run Time Key, powering up, or switching back to continuous mode from timer mode. |
|-----|------------------|--|--|
| sec | Time Unit        | second   |  |
| min | Time Unit        | minute   | Only one icon can be   |
| hr  | Time Unit        | hour   | displayed at a time.   |
| rpm | Speed Unit       | rpm  |  |

### 3.2 Operating Instructions

# 3.2.1 Power Up

GM200-2A operates on DC24V/8W, GM400-2A operates on DC24V/16W. The pump can be powered by connecting to a single-phase mains supply using the AC100-240V to DC24V adapter provided by Longer Pump.


Upon power-up, the pump remains in a stopped status. The work mode and parameters will be retained from the previous power-off status.

#### 3.2.2 Set the Work Mode

The pump can run in continuous mode or timer mode. When the pump is stopped, press the Mode Key to toggle between the two modes. The timer icon will be displayed when timer mode is active.

In timer mode, press the Start/Stop Key or a footswitch to start the pump. The pump will stop automatically when the set timer duration expires, or it can be manually stopped by pressing the Start/Stop Key or a footswitch.

♦ Note: the mode can not be changed when the pump is running.



### 3.2.3 Display Pump Speed or Time

Whether pump is running or stopped, press the Unit Key to toggle the display between pump speed and time.

- a. Continuous mode: the displayed time represents the total run time accumulated over multiple start-stop cycles.
- b. Reset the accumulated run time:

  When LCD displays the run time, press the Increase and Decrease Keys at the same time to reset the accumulated run time. If the pump is running at this time, it will automatically start counting from zero.
- ♦ Note: the accumulated time will be reset automatically when pump powered up, or switching back to continuous mode from timer mode.
- c. Timer mode: the displayed time represents the set timer duration (when the pump is stopped) or remaining countdown time (when the pump is running)
- ♦ Note: In timer mode, the pump can not be paused. When restarted, the countdown will begin from the full set duration.

#### 3.2.4 Set the Timer Duration

#### a. Set the time unit:

In timer mode, when the pump is stopped, short press the Unit Key to display the set timer duration (in seconds, minutes or hours). Then, long press the Unit Key to cycle through the time units: sec (seconds), min (minutes), and hr (hours).

b. Set the timer duration with the Increase or Decrease Keys:

In timer mode, when the pump is stopped, short press the Unit Key to display the set timer duration (in seconds, minutes or hours). Use the Increase Key or Decrease Key to adjust the timer value. Long press the Increase or Decrease Key to adjust the value quickly.

Timer range: 0.1s to 999hrs.

#### 3.2.5 Start and Stop

When the pump is stopped (display speed or time), short press the Start/Stop Key , the pump will run at the set speed and direction. The running status indicated on the screen will be .

When the pump is running (display speed or time), short press the Start/Stop Key , the pump will stop. The running status indicated on the screen will be .

♦ Note: When the keypad is locked and the pump is running, long press the Start/Stop Key for more than one second, the pump will be stopped and the keypad will be unlocked.



**Running Status** 



Stop Status

#### 3. 2. 6 Change the Direction

When the pump is stopped or running (displays speed or time), press the Direction Key , the pump will toggle the running direction between clockwise and counter-clockwise.

♦ Note: the direction can not be changed when the pump is in prime status (displays "---").



Clockwise




Counter-clockwise

#### 3.2.7 Prime the Pump

When the pump is stopped or running (displays speed or time), press the Max Key to prime the pump at full speed 200rpm/ 400rpm and in the direction indicated. Press the key again to return to the previous status. When pump is in the prime status, the pump can be stopped by pressing Start/Stop Key , but the Direction Key is disabled.

In continuous mode, the accumulated running time continues during prime status.

In timer mode, the countdown of the remaining time continues during prime status.



Display the Speed in the Prime Status (Continuous mode)

Display the Accumulated Run Time in the Prime status (Continuous mode)



Display the Speed in the Prime Status (Timer mode)

Display the Remaining Time in the Prime status (Timer mode)

#### 3.2.8 Increase and Decrease Pump Speed

a. Using Increase and Decrease Keys:

When the pump is stopped or running, press the Unit Key to display current speed in rpm. Then press the Increase or Decrease Keys to adjust the pump speed. Press and hold the keys will quickly adjust the speed until the maximum of 200rpm/ 400rpm or minimum of 0.01rpm.

b. Change the speed unit:

When the pump is stopped, press the Unit Key to display current speed in rpm. Then long press the Unit Key to cycle through the speed units: 0.01rpm, 0.1rpm and 1rpm.

# 3.2.9 Keypad Lock

When the pump is stopped or running (displays speed or time), short press the Lock Key to lock the keypad, then the lock icon will appear.

Then long press the Lock Key to unlock the keypad, and the lock icon will disappear.

♦ Note: when the pump is running and the keypad is locked, long press the Start/Stop Key , the pump will stop and the keypad will be unlocked.

#### 3.2.10 Footswitch Control Start and Stop

The pump can be controlled by a footswitch, functioning the same as the Start/Stop Key. Each press of the footswitch toggles the pump between running and stopped statuses.

The footswitch and the Start/Stop Key remain functional simultaneously.

#### 4. GM200-1A/GM400-1A Operating Instructions

# 4.1 Keypad and Display



#### 4.1.1 Keypad Function

| Keys           | Keypad Control Mode<br>(continuous or timer)   | External Signal<br>Control Mode<br>(0-10kHz/ 4-20mA/<br>0-10V/ 0-5V)   | Communication<br>Control Mode<br>(RS485)   |
|----------------|--|--|--|
| Start/Stop Key | 1.Press the key to start or stop the pump. 2.When the pump is in the prime status via the Max Key, it also can be stopped by pressing this key. 3.When the pump is running and the keypad is locked, long pressing this key can unlock the keypad and stop the pump. | When the pump is running and the keypad is locked/unlocked, long pressing this key can activate the emergency stop function and stop the pump. | When the pump is running and the keypad is locked/unlocked, long pressing this key can activate the emergency stop function and stop the pump. |
| Direction Key  | Press the key to toggle the pump running direction, clockwise or counterclockwise.  The direction key is disabled when the pump is in the prime status via Max Key.  | Disabled   | Disabled   |
| Increase Key   | Increase the pump speed or timer duration. Press and hold the key will increase the value quickly.   | Disabled   | Select the communication control parameters: pump address, baud rate, parity.  |
| Decrease Key   | Decrease the pump speed or timer<br>duration. Press and hold the key<br>will decrease the value quickly.   | Disabled   | Select the<br>communication<br>control parameters:<br>pump address, baud<br>rate, parity.  |

| Clear Run<br>Time Keys | Press the Increase and Decrease key<br>reset the accumulated run time. Thi<br>whether pump is running or stoppe   | Disabled  |   |
|------------------------|---|---|---|
| Max Key                | Press the Max Key to prime the pump at full speed 200rpm or 400rpm, whether the pump is running or stopped. Press the key again to return to the previous status. |   | Disabled  |
| SET Key                | Disabled  | Confirm the control mode: when changing the control mode, short press the SET key to confirm and enter the selected the control mode, and the corresponding running screen will be displayed. | When RS485 is selected, short press the SET key to confirm and enter the communication control mode, and the corresponding running screen will be displayed.  Set the communication control parameters: When the pump is in RS485 control mode and the pump stops, short press the SET key to enter the communication parameter setting screen.  The parameters can be set: pump address, baud rate and parity. After select the parameters by pressing the Increase and Decrease Keys, short press the SET key to confirm the parameter setting and enter next parameter setting and enter next parameter setting screen.  The pump will not receive a new communication control command when displaying the parameter setting screen. |

19

Lock Key

#### 1.Lock the keypad:

Short press the Lock Key to lock the keypad. Only Stop Key and Lock Key will be functional. Other keys will be disabled.

#### 2. Unlock the keypad:

mode:

- a. When the pump is running or stopped and the keypad is locked, long press the Lock Key (> 1 second) to unlock the keypad. All keys will then be functional.
- b. When the pump is running and the keypad is locked, long press the Start/Stop Key (> 1 second) to stop the pump and unlock the keypad.

#### a.Pump running: short press the Unit Key to toggle the display between pump speed and accumulated run time.

1. Pump in the continuous work

b.Pump stopped: short press the Unit Key to toggle the display between pump speed and accumulated run time. When LCD displays the pump speed, long press the Unit Key to cycle through the speed units (0.01rpm. 0.1rpm and 1rpm).

#### 2. Pump in the timer work mode:

- a.Pump running: short press the Unit Key to toggle the display between pump speed and remaining run time.
- b.Pump stopped: short press the Unit Key to toggle the display between pump speed and timer duration. When LCD displays the pump speed, long press the Unit Key to cycle through the speed units (0.01rpm, 0.1rpm and 1rpm). When LCD displays the timer duration, long press the Unit Key to cycle through the time units (sec, min and hour).

When the pump is running or stopped, short press the Unit Key to toggle the display between pump speed and accumulated run time.

# 1.Pump in the continuous work mode:

When the pump is running or stopped, short press the Unit Key to toggle the display between pump speed and accumulated run time.

# 2.Pump in the timer work mode:

- a.Pump running: short press the Unit Key to toggle the display between pump speed and remaining run time.
- b.Pump stopped: short press the Unit Key to toggle the display between pump speed and timer duration.




Unit Kev

Mode Key

When the pump is stopped, press the Mode Key to cycle through the work mode and control mode: keypad control continuous mode, keypad control timer mode, 0-10kHz external control mode, 4-20mA external control mode, 0-10V external control mode, 0-5V external control mode, RS485 communication control mode.

# 4.1.2 LCD Display



| Icon    | Name                                   | Description  | Remark   |
|---------|--|--|--|
|         | Run                                    | This icon will be displayed when the pump is running   | Only one icon can be                                       |
|         | Stop                                   | This icon will be displayed when the pump is stopped   | displayed at a time.                                       |
| ♦       | Counter-<br>clockwise                  | This icon will be displayed when the pump is running counter-clockwise.  | Only one icon can be                                       |
| C       | Clockwise                              | This icon will be displayed when the pump is running clockwise.  | displayed at a time.                                       |
| 0       | Keypad Lock                            | The lock icon appears when the keypad is locked and disappears when the keypad is unlocked.  |  |
| 0       | Timer                                  | In keypad control mode or RS485 mode:<br>The timer icon indicates that the pump is<br>running in timer mode. When the icon is not<br>displayed, the pump is running in<br>continuous mode. |  |
| 0-10kHz | 0-10kHz<br>control mode                | Current control mode is external signal control, and the pump speed signal is 0-10kHz  |  |
| 4-20mA  | 4-20mA<br>control mode                 | Current control mode is external signal control, and the pump speed signal is 4-20mA   | Only one icon<br>can be displayed<br>at a time.            |
| 0-10V   | 0-10V<br>control mode                  | Current control mode is external signal control, and the pump speed signal is 0-10V  | No icon means<br>the control mode<br>is keypad<br>control. |
| 0-5V    | 0-5V<br>control mode                   | Current control mode is external signal control, and the pump speed signal is 0-5V   |  |
| RS485   | RS485<br>communication<br>control mode | Current control mode is RS485 communication control mode   |  |

| 888 | Parameters/<br>Status | 1.Displays the current pump speed with the unit of "rpm"  2.Displays time with unit of "sec, min or hr": a.Pump stopped in the timer mode: displays the set timer duration.  b.Pump running in the timer mode: displays the remaining time (countdown).  c.Continuous mode: displays the accumulated run time.  3.Displays the communication parameters: pump address, baud rate, parity.  4.Displays "": when the pump is in the prime status.  5.Displays "SET": ready for remote control mode  6.Displays "E-S": in the emergency stop status by long pressing the Start/Stop Key | 1.In timer mode, the pump can not be paused. When restarted, the countdown time will begin from the full set duration. 2.In continuous mode, the accumulated run time can be reset by the Clear Run Time Key, powering up, or switching back to continuous mode from timer mode. |
|-----|-----------------------|--|--|
| sec | Time Unit             | second   |  |
| min | Time Unit             | minute   | Only one icon can be   |
| hr  | Time Unit             | hour   | displayed at a time.   |
| rpm | Speed Unit            | rpm  |  |

#### 4.2 Power Up

GM200-1A operates on DC24V/8W, GM400-1A operates on DC24V/16W. The pump can be powered by connecting to a single-phase mains supply using the AC100-240V to DC24V adapter provided by Longer Pump.

The work mode and parameters when powered up will be retained from the previous power-off status. Pump status when powered up is related to the work mode and control mode:

- a. Keypad control continuous mode: stop as default, can be set to the status before power-off via communication command.
- b. Keypad control timer mode: stop
- c. 0-10kHz/ 4-20mA/ 0-10V/ 0-5V external control mode: the pump status depends on the input signal.
- d. Rs485 control mode: stop


#### 4.3 Set the Work and Control Mode


The pump can operate in 7 modes: keypad control continuous mode, keypad control timer mode, 0-10kHz mode, 4-20mA mode, 0-10V mode, 0-5V mode and RS485 mode. When the pump is stopped, short press the Mode Key to cycle through these 7 modes.

- ♦ Note: The mode can not be changed when the pump is running.
- Keypad control continuous mode: the pump speed can be set via the keypad; the start/stop can be set via keypad/ footswitch/ external control signal; the running direction can be set via keypad/ external control signal. When the pump is running, it will automatically record the runtime and can accumulate multiple operation periods.
- Keypad control timer mode: the pump speed and timer duration can be set via the keypad; the start/stop can be set via keypad/ footswitch/ external control signal; the running direction can be set via keypad/ external control signal. And the pump can stop automatically when the set timer duration expires.
- 0-10kHz mode: The start/stop, running direction and pump speed will be controlled by external signals. And the pump speed signal is 0-10kHz pulse signal.
- 4-20mA mode: The start/stop, running direction and pump speed will be controlled by external signals. And the pump speed signal is 4-20mA analog signal.
- 0-10V mode: The start/stop, running direction and pump speed will be controlled by external signals. And the pump speed signal is 0-10V analog signal.
- 0-5V mode: The start/stop, running direction and pump speed will be controlled by external signals. And the pump speed signal is 0-5V analog signal.
- Rs485 mode: The pump parameters and running status will be set by the communication control commands. The interface is RS485, the protocol is Modbus RTU or Longer Pump OEM protocol.

Change the mode: Short press the Mode Key to cycle through the modes: Keypad continuous  $\rightarrow$  Keypad timer $\rightarrow$  0-10kHz  $\rightarrow$  4-20mA  $\rightarrow$  0-10V  $\rightarrow$  0-5V  $\rightarrow$  Rs485. When the screen displays  $\bigcirc$  , short press the SET Key to enter

the corresponding control mode. To exit the current mode and switch to another, the pump must be stopped first, then short press the Mode Key





#### 4.4 Manual Operating

When the pump is in keypad control continuous mode or timer mode, the parameters can be set and the pump can be controlled via the keypad.



#### 4.4.1 Display Pump Speed or Time

Whether pump is running or stopped, press the Unit Key to toggle the display between pump speed and time.

- a. Continuous mode: the displayed time represents the total run time accumulated over multiple start-stop cycles.
- b. Reset the accumulated run time:
  When LCD displays the run time, press the Increase and Decrease Keys at the same time to reset the accumulated run time. If the pump is running at this time, it will automatically start counting from zero.
- ♦ Note: the accumulated time will be reset automatically when the pump powered up, or switching back to continuous mode from timer mode.
- c. Timer mode: the displayed time represents the set timer duration (when the pump is stopped) or remaining countdown time (when the pump is running)
- ♦ Note: In timer mode, the pump can not be paused. When restarted, the countdown will begin from the full set duration.

#### 4.4.2 Set the Timer Duration

- a. Set the time unit:

  In timer mode, when the pump is stopped, short press the Unit Key to display the set timer duration (in seconds, minutes or hours). Then, long press the Unit Key to cycle through the time units: sec (seconds), min (minutes), and hr (hours).
- b. Set the timer duration with the Increase or Decrease Keys:
  In timer mode, when the pump is stopped, short press the Unit Key
  to display the set timer duration (in seconds, minutes or hours). Use the
  Increase Key or Decrease Key to adjust the timer value. Long
  press the Increase or Decrease Key to adjust the value quickly.

# 4.4.3 Start and Stop

When the pump is stopped (display speed or time), short press the Start/Stop Key , the pump will run at the set speed and direction. The running status indicated on the screen will be .

When the pump is running (display speed or time), short press the Start/Stop Key, the pump will stop. The running status indicated on the screen will be .

♦ Note: When the keypad is locked and the pump is running, long press the Start/Stop Key for more than one second, the pump will be stopped and the keypad will be unlocked.







**Stop Status** 

Start/stop the pump via an external control signal (Start/Stop Key is disabled, and other keys are functional): connect the Pin 12 to Pin 8 of remote control port, then input the start/stop control signal to Pin 13. Refer to the Chapter 2.3.3 for details.

### 4.4.4 Change the Direction

When the pump is stopped or running (displays speed or time), press the Direction Key ,the pump will toggle the running direction between clockwise and counter-clockwise.

♦ Note: the direction can not be changed when the pump is in prime status (displays "---").







Counter-clockwise

Control the running direction via an external control signal (Direction Key is disabled, and other keys are functional): connect the Pin 10 to Pin 8 of remote control port, then input the direction control signal to Pin 6. Refer to the Chapter 2.3.3 for details.

#### 4.4.5 Prime the Pump

When the pump is stopped or running (displays speed or time), press the Max Key to prime the pump at full speed 200rpm/ 400rpm and in the direction indicated. Press the key again to return to the previous status. When the pump is in the prime status, the pump can be stopped by pressing Start/Stop Key, but the Direction Key is disabled. In continuous mode, the accumulated running time continues during prime status.

In timer mode, the countdown of the remaining time continues during prime status.



Display the Speed in the Prime Status (Continuous mode)

Display the Accumulated Run Time in the Prime status (Continuous mode)



Display the Speed in the Prime Status (Timer mode)

Display the Remaining Time in the Prime status (Timer mode)

# 4.4.6 Increase and Decrease Pump Speed

a. Using Increase and Decrease Keys:

When the pump is stopped or running, press the Unit Key to display current speed in rpm. Then press the Increase or Decrease Keys to adjust the pump speed. Press and hold the keys will quickly adjust the speed until the maximum of 200rpm/ 400rpm or minimum of 0.01rpm.

b. Change the speed unit:

When the pump is stopped, press the Unit Key to display current speed in rpm. Then long press the Unit Key to cycle through the speed units: 0.01rpm, 0.1rpm and 1rpm.

# 4.4.7 Keypad Lock

When the pump is stopped or running (displays speed or time), short press the Lock Key to lock the keypad, then the lock icon will appear.

Then long press the Lock Key to unlock the keypad, and the lock icon will disappear.

♦ Note: when the pump is running and the keypad is locked, long press the Start/Stop Key , the pump will stop and the keypad will be unlocked.

# 4.5 Footswitch Control Start and Stop

When the pump is in the keypad control mode, the pump can be controlled by a footswitch, functioning the same as the Start/Stop Key. Each press of the footswitch toggles the pump between running and stopped statuses. The footswitch and the Start/Stop Key remain functional simultaneously.

#### 4.6 External Signal Control

The start/stop, running direction and pump speed can be controlled by external signals. Please refer to the Chapter 2.3.3 for the remote control port definition, and connect the control signals.


♦ Note: Disconnect the pump from the mains power before connecting the control signal wire.


#### 4.6.1 Set the Control Mode

GM200-1A and GM400-1A have 4 external control modes: 0-10kHz mode, 4-20mA mode, 0-10V mode, 0-5V mode. When the pump is stopped, short press the Mode Key to switch the control mode and set the control mode based on the pump speed signal.

When the pump is in the keypad control mode, the start/stop and running direction also can be controlled by external signals (speed, timer and other functions will be set via the keypad):

- a. Start/stop the pump via an external control signal (Start/Stop Key is disabled, and other keys are functional): connect the Pin 12 to Pin 8 of remote control port, then input the start/stop control signal to Pin 13. Refer to the Chapter 2.3.3 for details.
- b. Control the running direction via an external control signal (Direction Key is disabled, and other keys are functional): connect the Pin 10 to Pin 8 of remote control port, then input the direction control signal to Pin 6. Refer to the Chapter 2.3.3 for details.





When the pump is in external signal control mode, and the pump is running, long press the Start/Stop Key to stop the pump first, then short press Mode Key to switch the control mode.

### 4.6.2 Start and Stop

In the external control mode, the start/stop can be controlled by a dry contact signal or logic level signal (5-24V as high).

The control logic can be set by the communication commands. Refer to Appendix B, Modbus Register Definition, register 0x0031.

Default control logic: level trigger (momentary), pump runs when the start/stop input Pin 13 is left floating or high level, pump stops when the Pin 13 is connected to Pin 8 (GND).

- ♦ Note: to change the control logic, stop the pump first, then send the setting commands.
- 1. The start/stop trigger logic can be configured via communication commands as follows:
  - a. Level trigger (momentary), pump runs when the start/stop input Pin 13 is left floating or high level, pump stops when the Pin 13 is connected to Pin 8 (GND).

- b.Level trigger (momentary), pump stops when the start/stop input Pin 13 is left floating or high level, pump runs when the Pin 13 is connected to Pin 8 (GND).
- c.Pulse trigger (maintained), start/stop will switch on the falling edge signal to Pin 13.
- d.Pulse trigger (maintained), start/stop will switch on the rising edge signal to Pin 13.
- 2. When the trigger logic is set to level trigger and the start/stop input Pin 13 receives a start signal, the pump's power-up status (running or stopped) can be configured via communication commands. Refer to Appendix B, Modbus Register Definition, register 0x0031, for details.
- 3. In external control mode, whether the start/stop signal is enabled can be set through communication commands. Refer to Appendix B, Modbus Register Definition, register 0x0031, for details.
- a. The start/stop signal is enabled: a start/stop signal must be input to control the pump's start/stop status (default setting).
- b. The start/stop signal is disabled: the pump's start/ stop status is only controlled by the speed signal. speed = 0rpm, the pump stops; speed ≠ 0rpm, the pump runs.

# 4.6.3 Change the Direction

In the external control mode, the running direction can be controlled by a dry contact signal or logic level signal (5-24V as high).

The control logic can be set by the communication commands. Refer to Appendix B, Modbus Register Definition, register 0x0032.

Default control logic: level trigger (momentary), pump runs clockwise when direction input Pin 6 is left floating or high level, pump runs counterclockwise when direction input Pin 6 is connected to Pin 8 (GND).

♦ Note: to change the control logic, stop the pump first, then send the setting commands.

The direction trigger logic can be configured via communication commands as follows:

a. Level trigger (momentary), pump runs clockwise when direction input Pin 6 is left floating or high level, pump runs counterclockwise when direction input Pin 6 is connected to Pin 8 (GND).


- b. Level trigger (momentary), pump runs counterclockwise when direction input Pin 6 is left floating or high level, pump runs clockwise when direction input Pin 6 is connected to Pin 8 (GND).
- c. Pulse trigger (maintained), running direction will switch on the falling edge signal to Pin 6.
- d. Pulse trigger (maintained), running direction will switch on the rising edge signal to Pin 6.

#### 4.6.4 Increase and Decrease Pump Speed

The pump speed is linearly proportional to the speed control signal. The relationship between the signal range and speed range can be configured through communication commands. Refer to Appendix B, Modbus Register Definition, registers from 0x0034 to 0x003D, for details. Default setting:


GM200-1A: the 4-20mA/0-5V/0-10V/0-10kHz signal linearly corresponds to 0-200rpm.

GM400-1A: the 4-20mA/0-5V/0-10V/0-10kHz signal linearly corresponds to 0-400rpm.



#### 4.6.5 Manual Emergency Stop

In the external control mode, when the pump is running, long press the Start/Stop Key to stop the pump and display the emergency stop status . Then short press the Start/Stop Key to return to the current control mode, or short press the Mode Key to exit current control mode and display next mode ready screen.



# 4.6.6 Display Pump Speed or Accumulated Time

In the external control mode, whether pump is running or stopped, press the Unit Key to toggle the display between pump speed and the accumulated time over multiple start-stop cycles.

Reset the accumulated run time: When LCD displays the run time, press the Increase and Decrease Keys at the same time to reset the accumulated run time. If the pump is running at this time, it will automatically start counting from zero.

♦ Note: the accumulated time will be reset automatically when pump powered up, or switching back from other mode.

#### 4.6.7 Keypad Lock

When the pump is stopped or running (displays speed or time), short press the Lock Key to lock the keypad, then the lock icon will disappear.

Then long press the Lock Key to unlock the keypad, and the lock icon will disappear.

♦ Note: when the pump is running and the keypad is locked, long press the Start/Stop Key , the pump will stop and the keypad will be unlocked, and the emergency stop status will be displayed.


#### 4.7 Communication Control

GM200-1A and GM400-1A are equipped with RS485 interface, which allows setting running parameters and controlling pump operation via communication commands according to Modbus RTU protocol or Longer Pump OEM protocol. Refer to Appendix B and C for details.

Communication control function: start/stop the pump, change the running direction, prime the pump, set the pump speed, set the work mode as continuous or timer, set the timer duration, reset the accumulated run time, set the communication parameters (pump address, baud rate, parity).

#### 4.7.1 Enter and Exit RS485 Mode

Enter RS485 mode: short press the Mode Key to switch the mode to RS485, displaying RS485 and FFT. Then short press the SET Key to enter the RS485 mode.



Exit RS485 mode: When pump stops, short press the Mode Key to exit the RS485 mode and enter the keypad continuous mode.

#### 4.7.2 Set the Communication Parameters

#### a. Modbus RTU Protocol:

Parameter default settings: pump address: 1, baud rate: 1200bps, even parity, 1 stop bit

Pump address range: 1-30, and 0 is the broadcast address.

Baud rate options: 1200bps, 9600bps, 19200bps, 38400bps, 115200bps

Parity options: none, even, odd

Stop bit can not be set.

Modbus RTU parameters can be set through the keypad and communication commands. Refer to the Appendix B for the registers.

#### b. Longer Pump OEM protocol:

Parameter default settings: pump address: 1, baud rate: 1200bps, even parity, 1 stop bit

Pump address range: 1-30, and 31 is the broadcast address.

Baud rate options: 1200bps, 9600bps, 19200bps, 38400bps, 115200bps

Parity options: none, even, odd


Stop bit can not be set.

Longer Pump OEM parameters can be set through the keypad.

#### c. Set the parameters through the keypad:

In the RS485 mode, when pump stops, short press the SET Key enter the parameter setting screen. The parameters can be set: pump address, baud rate, parity.

Press the Increase and Decrease Keys to select the parameters, then press the SET Key to confirm the parameter and enter next parameter setting screen.



Pump address: A01 represents address of 1, A30 represents address of 30 Baud rate: 1.2 represents 1200bps, 9.6 represents 9600bps, 19.2 represents 19200bps, 38.4 represents 38400bps, 115 represents 115200bps Parity: P-O represents odd, P-E represents even, P-N represents none.

♦ Note: the pump can not receive communication commands when displaying communication parameter setting screen.

#### 4.7.3 Set the Continuous or Timer Mode

The work mode can be set to continuous mode or timer mode through communication commands. Refer to Appendix A or B for details.

Continuous mode: both starting or stopping the pump must be performed by sending the communication commands. The pump will automatically record the running time. Timer mode: starting the pump by sending the communication command. The pump can stop automatically when the set timer duration expires.






RS485 Continuous Mode

RS485 Timer Mode

#### 4.7.4 Manual Emergency Stop

In the RS485 control mode, when the pump is running, long press the Start/Stop Key to stop the pump and display the emergency stop status . Then short press the Start/Stop Key to return to the RS485 control mode, or short press the Mode Key to exit Rs485 control mode and display keypad continuous mode.



39

#### 4.7.5 Display Pump Speed or Time

Whether pump is running or stopped, press the Unit Key to toggle the display between pump speed and time.

- a. Continuous mode: the displayed time represents the total run time accumulated over multiple start-stop cycles.
- b. Reset the accumulated run time: by using communication command, refer to Appendix B and C.
- ♦ Note: the accumulated time will be reset automatically when pump powered up, or switching back to RS485 mode.
- c. Timer mode: the displayed time represents the set timer duration (when the pump is stopped) or remaining countdown time (when the pump is running).
- ♦ Note: In timer mode, the pump can not be paused. When restarted, the countdown will begin from the full set duration.

### 4.7.6 Keypad Lock

When the pump is stopped or running (displays speed or time), short press the Lock Key to lock the keypad, then the lock icon will appear. Then long press the Lock Key to unlock the keypad, and the lock icon will disappear.

# **Appendix A Factory Default Settings**

Reset the pump to the factory default settings: During power-up, long press the Mode Key until "---" appears on the display. Then, short press the Increase Key to display "FFF". Finally, short press the Max Key to reset the pump to the factory default settings.

| Product model  | GM200-1A  | GM200-2A             | GM400-1A  | GM400-2A             |
|--|---|----------------------|---|----------------------|
| Work mode  | Keypad<br>continuous  | Keypad<br>continuous | Keypad<br>continuous  | Keypad<br>continuous |
| Pump speed   | 200rpm  | 200rpm               | 400rpm  | 400rpm               |
| Run direction  | Clockwise   | Clockwise            | Clockwise   | Clockwise            |
| Timer duration   | 60s   | 60s                  | 60s   | 60s                  |
| Max speed to the max speed signal                          | 200   | /                    | 400   | /                    |
| Min speed to the min speed signal                          | 0   | /                    | 0   | /                    |
| Start/stop trigger   | Pump runs when<br>control pin is at high<br>level or left floating              | /                    | Pump runs when<br>control pin is at high<br>level or left floating              | /                    |
| Direction tigger   | Pump runs<br>clockwise when<br>control pin is at high<br>level or left floating | /                    | Pump runs<br>clockwise when<br>control pin is at high<br>level or left floating | /                    |
| Pump address   | 1   | /                    | 1   | /                    |
| Baud rate  | 1200bps   | /                    | 1200bps   | /                    |
| Parity   | Even  | /                    | Even  | /                    |
| Stop bit   | 1   | /                    | 1   | /                    |
| Pump status when<br>powered up<br>(keypad control<br>mode) | Stop  | Stop                 | Stop  | Stop                 |

# **Appendix B Modbus Register Definition**

Default communication parameters: pump address 1, baud rate 1200bps, even parity, 1 stop bit.

Pump address range: 1-30, and 0 is the broadcast address.

Baud rate options: 1200bps, 9600bps, 19200bps, 38400bps, 115200bps

Parity options: none, even, odd

Stop bit can not be set.

♦ Note: in any control mode (keypad control mode, external control mode, RS485 control mode), all registers can be read by commands.

| Function           | Parameter<br>Variable                        | Register<br>Address | Data<br>Type | Read/<br>Write | Parameter<br>Stored? | Default | Description   | Note  |
|--------------------|--|---------------------|--------------|----------------|----------------------|---------|---|---|
| Running<br>Control | Start/stop                                   | 0x0001              | uint_16      | R/W            | N                    | 0       | 0: stop<br>1: start   |   |
| Running<br>Control | Prime the pump at full speed                 | 0x0006              | uint_16      | R/W            | N                    | 0       | Exit prime status and return to the previous status     Prime the pump at full speed  |   |
| System             | Pum<br>address                               | 0x0010              | uint_16      | R/W            | Υ                    | 1       | Setting range: 1-30   | The command is valid when pump stops.   |
| System             | Baud rate                                    | 0x0011              | uint_16      | R/W            | Y                    | 0       | 0: 1200bps<br>1: 9600bps<br>2: 19200bps<br>3: 38400bps<br>4: 115200bps  | The<br>command<br>is valid<br>when<br>pump<br>stops.  |
| System             | Parity                                       | 0x0012              | uint_16      | R/W            | Υ                    | 2       | 0: non<br>1: old<br>2: even   | The command is valid when pump stops.   |
| System             | Enable<br>communica-<br>tion control<br>mode | 0x0020              | uint_16      | R/W            | N                    | 0       | 1: enable<br>When this register is<br>set to 1, the pump<br>directly enters RS485<br>mode. To switch from<br>RS485 to another<br>mode, manual<br>switching via keypad<br>is required. | The command is valid whether pump is running or stopped. The pump will stop first before switching to RS485 mode. |

| Function   | Parameter<br>Variable                                     | Register<br>Address |         | Read/<br>Write | Parameter<br>Stored? | Default | Description  | Note                                  |
|--|---|---------------------|---------|----------------|----------------------|---------|--|---------------------------------------|
| Parameters<br>for keypad<br>control                  | Pump<br>status when<br>power-up                           | 0x0021              | uint_16 | R/W            | Υ                    | 0       | 0: stop<br>1: return to the status<br>before power-off<br>Only valid for keypad<br>control continuous<br>mode.   | The command is valid when pump stops. |
| Parameters<br>for keypad<br>control                  | Disable<br>the<br>Direction<br>Key                        | 0x0022              | uint_16 | R/W            | Y                    | 0       | the Direction Key is enabled     the Direction Key is disabled, pump can only run clockwise.     Only valid for keypad control.  | The command is valid when pump stops. |
| Parameters<br>for the<br>external<br>control<br>mode | Start/sto<br>p control<br>logic via<br>external<br>signal | 0x0031              | uint_16 | R/W            | Y                    | 0x200   | b1-b0 00: Level trigger, pump runs when the start/stop input pin is left floating or high level, pump stops when the pin is connected to GND. 01: Level trigger, pump stops when the start/stop input pin is left floating or high level, pump runs when the pin is connected to GND. 10: Pulse trigger, start/stop will switch on the falling edge signal to start/stop input pin. 11: Pulse trigger, start/stop will switch on the rising edge signal to start/stop input pin. | The command is valid when pump stops. |

| Function   | Parameter<br>Variable                                    | Register<br>Address | Data<br>Type | Read/<br>Write | Parameter<br>Stored? | Default | Description  | Note                                  |
|--|--|---------------------|--------------|----------------|----------------------|---------|--|---------------------------------------|
| Parameters<br>for the<br>external<br>control<br>mode | Start/stop<br>control<br>logic via<br>external<br>signal | 0x0031              | uint_16      | R/W            | Y                    | 0x200   | b8:  0: the start/stop signal is enabled, and a start/stop signal must be input to control the pump's status.  1: the start/stop signal is disabled, and the pump's start/ stop status is only controlled by the speed = 0, the pump stops; speed = 0, the pump runs.  bit9:  0: when the trigger mode is set to level trigger, the pump remains stopped upon initial power-up. The start/stop signal must change from stop to start to make the pump start running.  1: when the trigger mode is set to level trigger, the pump's initial power-up start vunning.  1: when the trigger mode is set to level trigger, the pump's initial power-up status depends on whether the input signal is a start or stop signal.  Note:  1. When the trigger mode is set to level trigger, the pump's powered up status depends on the settings of bit 8 and bit 9, as well as the start/stop input signal.  2. When the trigger mode is set to pulse trigger and bit 8 is 0, the pump will be in a stopped status upon power-up. | The command is valid when pump stops. |

| Function   | Parameter<br>Variable  | Register<br>Address | Data<br>Type | Read/<br>Write | Parameter<br>Stored? | Default                        | Description  | Note                                  |
|--|--|---------------------|--------------|----------------|----------------------|--------------------------------|--|---------------------------------------|
| Parameters<br>for the<br>external<br>control<br>mode | Running<br>direction<br>control<br>logic via<br>external<br>signal | 0x0032              | uint_16      | R/W            | Y                    | 0                              | b1-b0  00: Level trigger, pump runs clockwise when direction input pin is left floating or high level, pump runs counterclockwise when direction input pin is connected to GND.  01: Level trigger, pump runs counterclockwise when direction input pin is left floating or high level, pump runs clockwise when direction input pin is left floating or high level, pump runs clockwise when direction input pin is connected to GND.  10: Pulse trigger, running direction will switch on the falling edge signal to direction will switch on the rising edge signal to direction input pin. | The command is valid when pump stops. |
| Parameters<br>for the<br>external<br>control<br>mode | Max speed<br>correspond<br>-ing to the<br>max speed<br>signal      | 0x0034              | uint_16      | R/W            | Y                    | GM200:<br>200<br>Gm400:<br>400 | (min speed set in 0x0035 +1rpm) to the max speed of the pump. Data unit: 0.01rpm Max speed of the pump: GM200: 200rpm GM400: 400rpm  | The command is valid when pump stops. |
|  | Max speed<br>correspond<br>-ing to the<br>max speed<br>signal      | 0x0035              | uint_16      | R/W            | Y                    | 0                              | 0rpm to (max speed<br>set in 0x0034 -1rpm)<br>Data unit: 0.01rpm   | The command is valid when pump stops. |
|  | 0-5V speed<br>control,<br>min signal                               | 0x0036              | uint_16      | R/W            | Y                    | 0                              | 0V to (max input set in<br>0x0037 -1V)<br>Data unit: 0.01V   | The command is valid when pump stops. |

| Function                    | Parameter<br>Variable                      | Register<br>Address | Data<br>Type | Read/<br>Write | Parameter<br>Stored? | Default | Description   | Note                                  |
|-----------------------------|--|---------------------|--------------|----------------|----------------------|---------|---|---------------------------------------|
|                             | 0-5V speed<br>control,<br>max signal       | 0x0037              | uint_16      | R/W            | Y                    | 500     | (min input set in 0x0036 +1V) to 5V Data unit: 0.01V                | The command is valid when pump stops. |
|                             | 0-10V<br>speed<br>control,<br>min signal   | 0x0038              | uint_16      | R/W            | Y                    | 0       | 0V to (max input<br>set in 0x0039 -1V)<br>Data unit: 0.01V          | The command is valid when pump stops. |
| Parameters<br>for the       | 0-10V<br>speed<br>control,<br>min signal   | 0x0039              | uint_16      | R/W            | Y                    | 1000    | (min input set in 0x0038 +1V) to 10V Data unit: 0.01V               | The command is valid when pump stops. |
| external<br>control<br>mode | 4-20mA<br>speed<br>control,<br>min signal  | 0x003A              | uint_16      | R/W            | Y                    | 400     | 4mA to (max input<br>set in 0x003B -<br>1.6mA)<br>Data unit: 0.01mA | The command is valid when pump stops. |
|                             | 4-20mA<br>speed<br>control,<br>max signal  | 0x003B              | uint_16      | R/W            | Y                    | 2000    | (min input set in<br>0x003A +1.6mA) to<br>20mA<br>Data unit: 0.01mA | The command is valid when pump stops. |
|                             | 0-10kHz<br>speed<br>control,<br>min signal | 0x003C              | uint_16      | R/W            | Y                    | 0       | 0 to (max input set in<br>0x003D-1kHz)<br>Data unit: 1Hz            | The command is valid when pump stops. |
|                             | 0-10kHz<br>speed<br>control,<br>max signal | 0x003D              | uint_16      | R/W            | Y                    | 10000   | (min input set in<br>0x003C +1kHz) to<br>10kHz<br>Data unit: 1Hz    | The command is valid when pump stops. |
| Running<br>Control          | Direction                                  | 0x0060              | uint_16      | R/W            | Y                    | 1       | 0: clockwise<br>1: counterclockwise                                 |                                       |
| Running<br>Control          | Work<br>mode                               | 0x0062              | uint_16      | R/W            | Y                    | 7       | 4: timer mode<br>7: continuous mode                                 |                                       |

| Function           | Parameter<br>Variable                                     | Register<br>Address |         | Read/<br>Write | Parameter<br>Stored? | Default                        | Description  | Note                                  |
|--------------------|---|---------------------|---------|----------------|----------------------|--------------------------------|--|---------------------------------------|
| Running<br>Control | Timer<br>duration   | 0x0065              | uint_16 | R/W            | Υ                    | 600                            | 1 - 999  | The command is valid when pump stops. |
| Running<br>Control | Timer<br>unit   | 0x0066              | uint_16 | R/W            | Y                    | 99                             | 99:0.1s<br>100: 1s<br>101: 0.1min<br>102: 1min<br>103: 0.1h<br>104: 1h   | The command is valid when pump stops. |
| Running<br>Control | Pump<br>speed   | 0x0069              | uint_16 | R/W            | Y                    | GM200:<br>200<br>Gm400:<br>400 | 0 to 999   |                                       |
| Running<br>Control | Speed<br>unit   | 0x006A              | uint_16 | R/W            | Y                    | 100                            | 98: 0.01rpm<br>99: 0.1rpm<br>100: 1rpm   |                                       |
| Running<br>Control | Accumulated<br>run time<br>(most<br>significant<br>byte)  | 0x0109              | uint_16 | R/W            | N                    | 0                              | Unit: 10ms Read the register for the accumulated run time Write 0 to the register to reset the accumulated run time. |                                       |
| Running<br>Control | Accumulated<br>run time<br>(least<br>significant<br>byte) | 0x010A              | uint_16 | R/W            | N                    | 0                              | Unit: 10ms Read the register for the accumulated run time Write 0 to the register to reset the accumulated run time. |                                       |

# Appendix C Longer Pump OEM Protocol

Parameter default settings: pump address: 1, baud rate: 1200bps, even parity, 1 stop bit

Pump address range: 1-30, and 31 is the broadcast address.

 $Baud\ rate\ options:\ 1200bps,\ 9600bps,\ 19200bps,\ 38400bps,\ 115200bps$ 

Parity options: none, even, odd

Stop bit can not be set.

- 1. Frame format: 1start + 8data + parity + 1stop
- 1 start bit
- 8 data bits
- 1 parity bit (non, odd or even)
- 1 stop bit
- 2. Message format: flag+ addr + len + pdu + fcs

flag:E9H, the message head. When sending the message, the data E8H after message head will be replaced with E8H 00H, and E9H after message head will be replaced with E8H 01H. When receiving the message, the data E8H 00H after message head will be reverted to E8H, and E8H 01H after message head will be reverted to E9H. (Note: if E8 00 replaced E8 or E8 01 replaced E9, E8 00 or E8 01 will be regarded as one byte, no influence on the length of pdu.)

addr: one byte, pump address, 1-30. 31 is broadcast address.

len: one byte, length of pdu.

fcs:one byte, XOR of addr, len, pdu.

- 3. pdu format: application layer code format
- 3.1 Set the pump running parameters (continuous mode)

Send to the pump:

WJ Speed (2 bytes)

(2 bytes) Full speed and start/stop (1 byte)

Direction (1 byte)

Pump responds:


WJ

♦ Note: The addr in message can be pump address (1-30) or broadcast address 31. All pumps will operate according to the same command without response when using broadcast address.

#### LONGER Instructions for use of peristaltic pump

# LONGER Instructions for use of peristaltic pump


3.2 Read the pump running status (continuous mode)



- ♦ Note: When reading the running status, the addr in the message only can be pump address (1-30).
- 3.3 Set the pump address:



- ♦ Note: When setting the pump address, the addr in the message can be pump address (1-30) or broadcast address 31. When using broadcast address, only one pump should be on the RS485 bus and be set with the new address, and no pump response.
- 3.4 Read the pump address:



♦ Note: When reading the pump address, the addr in the message only can be pump address (1-30). This command is only used to verify the pump address is correct. 3.5 Set the timer duration (timer mode):



Time unit: 99 - 0.1s, 100 - 1s, 101 - 0.1min, 102 - 1min, 103 - 0.1h, 104 - 1h Time value: 1 - 999°

- ♦ Note: The addr in message can be pump address (1-30) or broadcast address 31. All pumps will operate according to the same command without response when using broadcast address.
- ♦ Note:

Send to the pump:

- 1. If the pump needs to work in the timer mode, use WJ command to set the pump speed first and stop the pump. Then use WM command to set the timer duration, running direction, and start the pump. Then the pump will run in the timer mode, and count down the time. When the pump is running in the timer mode, the pump speed and direction can be changed by WJ command, and in the same command, the start/stop status should be start.
- 2. To exit the timer mode, use WJ or WM command to stop the pump first. Then use WJ command to start the pump, then the pump will run in continuous mode, and the pump will record the run time automatically.
- 3.6 Read the pump running status (timer mode)

| RM      |                      |                    |                                    |                    |
|---------|----------------------|--------------------|------------------------------------|--------------------|
| Pump re | esponds:             |                    |                                    |                    |
| RM      | Time value (2 bytes) | Time unit (1 byte) | Full speed and start/stop (1 byte) | Direction (1 byte) |

Time unit: 99 - 0.1s, 100 - 1s, 101 - 0.1min, 102 - 1min, 103 - 0.1h, 104 - 1h Time value: 1 - 999

Note: When reading the pump status, the addr in the message only can be pump address (1-30).

3.7 Reset the accumulated run time

Send to the pump :

WCT

Pump responds :

WCT

- ♦ Note: The addr in message can be pump address (1-30) or broadcast address 31. All pumps will operate according to the same command without response when using broadcast address.
- 3.8 Read the accumulated run time

Send to the pump :

RCT

Pump responds :

RCT

Accumulated run time (4 bytes)

Time unit: 10ms.

♦ Note: When reading the run time, the addr in the message only can be pump address (1-30).

### **Supplementary Information**

- 1. The ASCII codes of W, R, J, I, D, M, C, T are 57H, 52H, 4AH, 49H, 44H, 4DH, 43H, 54H
- 2. Pump speed is hexadecimal number, most signification byte first.

GM200: max speed is 200.0 rpm, data unit is 0.1rpm. Example: 07D0H means 200rpm.

GM400: max speed is 400 rpm, data unit is 1rpm. Example: 0190H means 400rpm.

3. Full speed and start/stop control:

Bit0: 1 means pump runs, 0 means pump stops.

Bit1: 1 means full speed, 0 means normal speed.

4. Direction control:

Bit0: 1 means CW, 0 means CCW.

- 5. addr default setting: 1
- 6. Examples:
- a. To set the pump GM200 (addr:01) to run clockwise with speed of 200rpm. The command string is as follows:

E9 01 06 57 4A 07 D0 01 01 CD

b. To set the pump GM400 (addr:01) to run clockwise with speed of 400rpm. The command string is as follows:

E9 01 06 57 4A 01 90 01 01 8B